

September 17, 2019

ADDENDUM No. 1

To become part of the Contract for the project:

**FUEL OIL TANK REPLACEMENT
ORCHARD HILL / PR SMITH SCHOOL
SOUTH WINDSOR, CT**

Following are changes to the Contract Documents based on discussions at the pre-bid walkthrough on 9/13/2019 and questions received during the bidding period:

1. On Drawing M-2, Detail 3, disregard the note “Provide New Oil Burners – 23.5 gph each.” The existing oil burners on the boilers are to remain. Reuse existing fusomatic valves, oil filter cannisters and return check valves. Provide new oil filter element.

+++++ END OF ADDENDUM No. 1 +++++
