

Q: Do you have a budget you're trying not to exceed?

A: These are PPA projects, so the project budget is irrelevant, technically. The district is looking for the right combination of the lowest PPA rate from the most experienced developer.

Q: Do you have an example of a project schedule?

A: We expect the developer to present their project schedule

Q: What is the estimation of the duration of the entire project?

A: We would expect complete delivery during the summer of 2024

Q: What annual production are you looking for?

A: Maximum utilization of the FTM high school roof and 90% production/consumption ratio for the BTM projects.

Q: Do you want a max fit? Or leave space?

A: We will evaluate your designs based on setback requirements and usable production

Q: Would you prefer contractors that are performing services in Connecticut?

A: The RFP requires each responder to have completed three similar project portfolios in Connecticut.

Q: Do you Give preference to minority owned business enterprise in the state of Connecticut?

A: No preference

Q: How much in terms of cents are you looking to receive in KWH

A: Each developer is encouraged to bring their most competitive PPA pricing to their response.

Q: Which building does meter # 81209181 represent?

A: Timothy Edwards

Q: Which Manufacture do you prefer? (SolarEdge, Enphase, etc.)

A: Equipment must be specified and be Tier 1 bankable equipment

Boston, MA 02127

88 Black Falcon, Suite 342
P.617.338.6300; F.617.542.4487

Rocky Hill, CT 06067

2275 Silas Deane Highway
P.860.436.3433; F.860.436.3459

Kingston, NH 03848

8 Williams Path
P.603.642.9591; F.603.642.6477



Q: How do you incorporate a RFP fee schedule?

A: Please see original RFP

Q: Are you open to having work done overnight or during school hours?

A: No work done overnight

Q: Do you have the usage for the other two sites?

A: Wapping: 250,000 kWh/year, rate 40 (might change to rate 30), Pleasant Valley: 350,000 kWh/year, rate 30

Q: Do you want separate pricing for each site or a all-inclusive cost for the entire project?

A: Separate PPA rates, per school

Q: Do you want backup batteries installed on any location?

A: Not part of the scope at this time

Boston, MA 02127

88 Black Falcon, Suite 342
P.617.338.6300; F.617.542.4487

Rocky Hill, CT 06067

2275 Silas Deane Highway
P.860.436.3433; F.860.436.3459

Kingston, NH 03848

8 Williams Path
P.603.642.9591; F.603.642.6477



Q: Are preliminary system sizes available for each of the sites, or should bidder propose their own designs?

A: Bidder to propose their own.

Q: Please confirm that all roofs hosting solar will have roof warranties in place for the full contract term.

A: Confirmed

Q: Is there an NRES price Bidders should assume for apples to apples comparison or should each Bidder make their own individual assumptions?

A: Use 2023 small NRES values and use \$135 for medium projects

Q: Please provide the utility rate for each site

A: We are only asking for PPA rates, no savings calculations at this time. HS and TEMS are rate 56, Pleasant Valley is rate 30, Wapping is rate 40.

If a VNM-style FTM project yields better economics than BTM netting for Timothy Edwards, feel free to propose that option.

Boston, MA 02127

88 Black Falcon, Suite 342
P.617.338.6300; F.617.542.4487

Rocky Hill, CT 06067

2275 Silas Deane Highway
P.860.436.3433; F.860.436.3459

Kingston, NH 03848

8 Williams Path
P.603.642.9591; F.603.642.6477